

# MOBILE FOOD VENDOR INSPECTION FORM

Updated: August, 2021

From the Office of the Fire Prevention Bureau – Phone (515) 283-4240



Name of Company \_\_\_\_\_  
Address \_\_\_\_\_  
Contact Person \_\_\_\_\_ Phone Number \_\_\_\_\_  
Email \_\_\_\_\_  
Truck; Make \_\_\_\_\_ Model \_\_\_\_\_ License Plate \_\_\_\_\_

## NOTES

- \_\_\_ **Exhaust Hood Type I** (Reference; 2018 IFC section 607)
  - \_\_\_ Filters \_\_\_\_\_
  - \_\_\_ Cleaning \_\_\_\_\_
  - \_\_\_ tags \_\_\_\_\_
  - \_\_\_ Records \_\_\_\_\_
  - \_\_\_ Fire extinguishing system \_\_\_\_\_
  - \_\_\_ Placard \_\_\_\_\_
- \_\_\_ **Fire Extinguishers** (Reference; 2018 IFC section 906)
  - \_\_\_ 2A:20BC \_\_\_\_\_
  - \_\_\_ Class K \_\_\_\_\_
- \_\_\_ **LP System** (Reference; NFPA 58, 2020 edition, section 6.26)
  - \_\_\_ Tanks Max. 2 = 50 gallons \_\_\_\_\_
  - \_\_\_ Tank mounting 6.26.3.4 \_\_\_\_\_
  - \_\_\_ Shutoff valve readily accessible 6.26.4.1 \_\_\_\_\_
  - \_\_\_ Caution plate 6.24.7.10 \_\_\_\_\_
  - \_\_\_ Outside 6.26.3.3 \_\_\_\_\_
  - \_\_\_ Inside (vapor tight cabinet) 6.26.3.3 \_\_\_\_\_
  - \_\_\_ Regulators (protected) 6.26.4.2 (B) \_\_\_\_\_
  - \_\_\_ Hoses 350psi marked LP gas (propane) 5.11.6.4 \_\_\_\_\_
  - \_\_\_ Fixed piping 6.26.5
    - \_\_\_ Fastened 6.26.5.1 \_\_\_\_\_
    - \_\_\_ Flexible connectors 6.26.5.1 (B) \_\_\_\_\_
    - \_\_\_ Protection at pass through points 6.26.5.1 (H) \_\_\_\_\_
- \_\_\_ **Egress** NFPA 58 section 6.26.7.9 \_\_\_\_\_
- \_\_\_ **Electrical** 2018 IFC section 604 \_\_\_\_\_
- \_\_\_ **General House Keeping / Storage** 2018 IFC section 315.1 \_\_\_\_\_

Based on the inspection completed above, the mobile food truck referenced in the information above **DOES / DOES NOT** (circle one) demonstrate **substantial compliance** with the adopted codes, standards and policies of the City of Des Moines Fire Department as witnessed on the date below.

Inspector \_\_\_\_\_ Signature \_\_\_\_\_ Date \_\_\_\_\_

Vendor \_\_\_\_\_ Signature \_\_\_\_\_ Date \_\_\_\_\_

Note: Vendor is to receive a copy of this completed form, the original is to be scanned and attached to FireHouse.